

TVOC Content Test Certificate

Friday, 10th March 2023

Supplier: Robert Designs International & Maxisil Pty Ltd (55 Lakewood Boulevard, Carrum Down, VIC, 3201, Australia)

Sample Description: Trade Grade Silicone sealant

Date Tested: March 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:


<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B</p>	<p align="center">Trade Grade Silicone sealant</p>
<p align="center">General Purpose Adhesives and Sealants Limit: 50 grams per litre</p>	<p align="center">37 grams per litre as VOC content per material</p>
<p align="center">Meets GBCA VOC Content Requirement</p>	<p align="center">Yes</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue Date: 10/3/2023

Expiry date: 10/03/2028

P23030015